

# PORTABLE APPLIANCE TESTING (PAT) CERTIFICATE

## DETAILS OF CLIENT

<b>Name:</b>	DJ Scott Dewing	<b>Telephone No:</b>	07817 909442
<b>Address:</b>	39 Warren Lane, Stanway, Colchester. info@scottdewing.co.uk	<b>Post Code:</b>	CO3 0LN

## TEST EQUIPMENT DETAILS

<b>Test equipment used:</b>	Seaward PrimeTest 100	<b>Serial No</b>	31J-0035	<b>Date of Test:</b>	17/06/2019
<b>Tested by:</b>	Karl Semmence	<b>No. of pages:</b>	1	<b>Next Test Due:</b>	16/06/2020

ID Number	Class or Lead	Location	Description	Result P or F	Comment
1	Class I	Mobile	dB Technology ES1203 Bass Cab w amp	Pass	
2	Class I	Mobile	Equinox Fusion Spot	Pass	
3	Class I	Mobile	Equinox Fusion Spot	Pass	
4	Class I	Mobile	Equinox Fusion Spot	Pass	
5	Class I	Mobile	Equinox Fusion Spot	Pass	
6	Lead	Mobile	6 way extension lead	Pass	13A Surge Protected
7	Lead	Mobile	6 way extension lead	Pass	13A Surge Protected
8	Lead	Mobile	6 way extension lead	Pass	13A Surge Protected
9	Lead	Mobile	2 way extension lead	Pass	10A
10	Lead	Mobile	2 way extension lead	Pass	10A
11	Lead	Mobile	2 way extension lead	Pass	10A
12	Class II	Mobile	PSU	Pass	
13	Lead	Mobile	Figure 8 to mains	Pass	3A
14	Class II	Mobile	Samsung TV	Pass	
15	Class II	Mobile	PSU	Pass	
16	Class II	Mobile	PSU	Pass	
17	Class II	Mobile	PSU	Pass	
18	Lead	Mobile	IEC to mains	Pass	13A
19	Lead	Mobile	IEC to mains	Pass	13A
20	Lead	Mobile	IEC to mains	Pass	13A
21	Lead	Mobile	IEC to mains	Pass	13A
22	Lead	Mobile	IEC to mains	Pass	13A
23	Lead	Mobile	Figure 8 to mains	Pass	3A
24	Class II	Mobile	PSU	Pass	
25	Lead	Mobile	Cloverleaf to mains	Pass	5A
26	Lead	Mobile	Cloverleaf to mains	Pass	5A
27	Class II	Mobile	PSU	Pass	
28	Class II	Mobile	PSU	Pass	
29	Class II	Mobile	PSU	Pass	
30	Class II	Mobile	PSU	Pass	
31	Class II	Mobile	PSU	Pass	
32	Class II	Mobile	PSU	Pass	
33	Lead	Mobile	2 way extension lead	Pass	13A Renewed plugs
34	Lead	Mobile	Powercon to mains	FAIL	Cord grip failed on powercon
34	Lead	Mobile	Powercon to mains	Pass	13A - Replaced cable
35	Class I	Mobile	LEDJ LED Dance Floor Power Unit	Pass	
36	Lead	Mobile	Cloverleaf to mains	Pass	5A
37	Class II	Mobile	PSU	Pass	
38	Lead	Mobile	IEC to mains	Pass	13A
39	Class I	Mobile	Mackie ProFX8 Mixer	Pass	
40	Class I	Mobile	Haze Machine	Pass	
41	Class II	Mobile	PSU	Pass	
42	Lead	Mobile	IEC to Multi IECs	Pass	In trussing
43	Lead	Mobile	IEC to Mains	Pass	In trussing

PATs tests carried out on items presented 17th June 2019 using Seaward PrimeTest 100 Calibrated on 17th December 2018